

146 Davison Road, Henniker New Hampshire 03242 Phone 603-428-3237 Fax 603-
428-3362

Email cogswellspring@henniker.org

Scheduled Water Shutdown Public Notice

**Monday, July 25, 2022 – 10:00 pm to
6:00 am next morning**

The Cogswell Spring Water Works has scheduled to perform water system improvements at the intersection of Main Street and Rush Road on Monday July 25, 2022.

As part of this work, a scheduled water shutdown will occur starting at 10:00 pm and lasting through to 6:00 am the next morning. This will effect properties on Main Street, Rush Road (to prospect Street) and Crescent Street.

Be sure to draw water sufficient for your needs before shut off. For drinking and cooking purposes fill clean containers and fill the bathtub with water for toilet flushing. Cogswell Spring Water Works apologizes in advance for any inconvenience that this shut down may cause you.

If you have a fire sprinkler or suppression system, please contact the Fire Department at 603-428-7552 to coordinate the necessary "Fire Watch" during this water shutdown period.

CSWW assumes no responsibility for damage on the premises as a result of the water being shut off. As a precaution against damage you can shut off the valve on your service pipe where it enters the house. This valve is located between the water meter and the wall of the house. You can call us at 603-428-3237 to get an update if the water is not restored by the time indicated.



STATE OF NEW HAMPSHIRE DEPARTMENT OF SAFETY

John J. Barthelmes, Commissioner



**Division of Fire Safety
OFFICE OF THE STATE FIRE MARSHAL
J. William Degnan, State Fire Marshal**

Office: NH Incident Management Center, 110 Smokey Bear Blvd.,
Concord, NH

Mailing Address: 33 Hazen Drive, Concord, NH 03305
603-223-4289, FAX 603-223-4294

Fire Watch Guidelines

When required by the fire chief or state fire marshal's office for building demolition and/or when there are situations that compromise the safety of the community, the fire chief or state fire marshal may require on-site personnel designated solely for fire watch purposes. The level of coverage shall be based upon the following guidelines; however, circumstances may warrant modifications at the discretion of the fire chief or state fire marshal:

LEVELS OF COVERAGE

LEVEL I:	CONTINUOUS MONITORING OF AFFECTED AREA FOR SIGNS OF SMOKE OR FIRE FOR THE SOLE PURPOSE OF NOTIFYING EMERGENCY SERVICES (DIALING 9-1-1)	ONE OR MORE APPROVED EMPLOYEES OF THE BUILDING OWNER; SECURITY GUARDS; OR QUALIFIED FIRE PERSONNEL
LEVEL II:	CONTINUOUS MONITORING OF AFFECTED AREA FOR SIGNS OF SMOKE OR FIRE FOR THE PURPOSE OF NOTIFYING EMERGENCY SERVICES AND ASSISTING WITH EVACUATION	ONE OR MORE APPROVED REPRESENTATIVES OR EMPLOYEES OF THE BUILDING OWNER; SECURITY GUARDS; OR QUALIFIED FIRE PERSONNEL – THESE INDIVIDUALS MUST BE FAMILIAR WITH THE EXITING SYSTEMS, FIRE PROTECTION SYSTEMS, AND EVACUATION PLANS RELATIVE TO THE EFFECTED AREA.
LEVEL III:	CONTINUOUS MONITORING OF EFFECTED AREA FOR SIGNS OF SMOKE OR FIRE FOR THE PURPOSES OF NOTIFYING EMERGENCY SERVICES, ASSISTING WITH EVACUATION, AND FIRE EXTINGUISHMENT / HAZARD MITIGATION	ONE OR MORE QUALIFIED FIRE PERSONNEL NOTE: AN EMERGENCY ACTION PLAN MAY BE REQUIRED.

Assembly Occupancies

Loss of a required fire alarm and/or fire sprinkler system prohibiting the use of the effected structure for large events – Level II or III

Special circumstances such as occupant load increase, nature of performance, EXHIBITION, DISPLAY, CONTEST OR ACTIVITY – LEVEL III

Business/Office Occupancies

Loss of a required fire alarm and/or fire sprinkler system – Level I as determined by the Fire Chief or State Fire Marshal – NOTE: All building occupants must be notified that the system/systems are out of service.

Educational Occupancies

Loss of a required fire alarm and/or fire sprinkler system – Level II while the building is occupied

NOTE: All staff must be notified of the failure.

Industrial Occupancies

Loss of any required fire alarm, fire sprinkler, and/or special system – Discretion of the Fire Chief or State Fire Marshal based upon the nature of hazard

Hazardous Occupancies

Loss of any required fire alarm, fire sprinkler, or special system – Level III depending on the nature of hazard as determined by the Fire Chief or State Fire Marshal

Institution/Healthcare Occupancies

Loss of any required fire alarm, fire sprinkler, and/or special system –Level I or higher at the discretion of the Fire Chief or State Fire Marshal based upon the nature of hazard.

Mercantile/Retail sales Occupancies

Loss of required fire alarm and/or fire sprinkler system – Level I

Residential/Hotel/Dormitory Occupancies

Loss of any required fire alarm, fire sprinkler, and/or special system – Level I or higher at the discretion of the Fire Chief or State Fire Marshal based upon the nature of hazard

Storage Occupancies

Loss of required fire alarm and/or fire sprinkler system – Stocked but no occupants: Level I; during operations – Level II; Hazardous Materials Permit required – Level III

Note - For all fire watch activities that involve fire personnel and/or equipment, fees may be assessed as set forth by local or state authority.